

VINYL WARNING LABELS ON THE ROLL



V5323 50x25mm



V5360 50x25mm



V5330 50x25mm



V5328 50x25mm



V5348 50x25mm



V5351 50x25mm



V5357 50x25mm



V5367 50x25mm



V5322 50x25mm



V5321 50x25mm

IMPORTANT
THIS INSTALLATION SHOULD BE PERIODICALLY TESTED AND INSPECTED AND A REPORT ON ITS CONDITION OBTAINED, AS PRESCRIBED IN THE REGULATIONS FOR ELECTRICAL INSTALLATIONS ISSUED BY THE INSTITUTE OF ELECTRICAL ENGINEERS

DATE OF LAST INSPECTION.....
RECOMMENDED DATE OF NEXT INSPECTION.....

VR2310 90x50mm

This installation, or part of it, is protected by a device which automatically switches off the supply if an earth fault develops. Test quarterly by pressing the button marked "T" or "Test". The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice.

VR2314 90x50mm



V53863 80x35mm



V5389 85x55mm



V5390 85x55mm

FREE EXILCO LABEL BOX
When you buy any 5 rolls listed above

Manufactured from durable vinyl- Quality Hot-foil printing. All labels are self-adhesive and perforated. 500 labels per roll (V5389, V5390, VR2310, VR2314 & V53863 - 250 per roll). An economical labelling solution.

RIGID PVC ELECTRICAL WARNING LABELS



ZKT5322 80x35mm



ZKT5360 80x35mm



ZKT5323 80x35mm



ZKT5351 80x35mm



ZKT5357 80x35mm



ZKT5321 80x35mm

IMPORTANT
THIS INSTALLATION SHOULD BE PERIODICALLY TESTED AND INSPECTED AND A REPORT ON ITS CONDITION OBTAINED, AS PRESCRIBED IN THE REGULATIONS FOR ELECTRICAL INSTALLATIONS ISSUED BY THE INSTITUTE OF ELECTRICAL ENGINEERS

DATE OF LAST INSPECTION.....
RECOMMENDED DATE OF NEXT INSPECTION.....

R2310 90x50mm



ZTM5348 60x80mm



ZTM5323 60x80mm



ZTM5375 60x80mm



HPZ5322 64x50mm



HPZ5355 64x50mm



ZKT5348 80x35mm



KT53863 35x80mm complete with cable tie (non-adhesive)

PHASE DISCS 20mm dia.

BS7671:2001 Amendment 2 colours

OLD colours

- Manufactured from 1mm rigid PVC
- Hot-foil printed for durability
- Supplied in packs of 5 labels
- All labels are self-adhesive



PZ53 50mm ea. side



HPZ5348 64x50mm



HPZ5323 64x50mm



HPZ5322 64x50mm

FREE EXILCO DISPLAY RACK
When you buy 10 packs of 12 items (5 labels per pack)

ELECTRIC SHOCK TREATMENT ARTIFICIAL RESPIRATION (Mouth to Mouth Method)

ACT AT ONCE

SAFEGUARD YOURSELF
Switch off power at the main switch. Use an object of good dielectric strength to remove the casualty from contact with the source of electricity.

START ARTIFICIAL RESPIRATION AT ONCE (If you are only a bystander, follow the RECOVER, CHECK and HELP instructions.)

- 1) Lay casualty on back. If inconvoluted, position on floor.
- 2) Remove spectacles if casualty's head. Press the nose of other hand against upper lip. Tuck the mouth of other hand under lower lip. Tuck the thumb of other hand under lower lip. Tuck the thumb of other hand under lower lip. Tuck the thumb of other hand under lower lip.
- 3) Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth.
- 4) Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth.
- 5) Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth. Seal your own hand around casualty's mouth.

WHEN CASUALTY STARTS TO BREATHE
Stop the mouth-to-mouth method. If the casualty is still unconscious, place them on their side and give first aid as appropriate.

EMERGENCY TEL. NO.

Shock Chart 260 x 330 mm

PORTABLE APPLIANCE TEST LABELS



- Self-adhesive paper labels
- Supplied in rolls of 500 labels
- Perforated for ease of use
- Size: 40 x 20 mm



Shown here are just a few examples of the whole EXILCO range of warning labels. For more information on the entire range and a free wall chart please contact our sales office

Tel: (01562) 823034 Fax: (01562) 829787

ALL LABELS ARE EX-STOCK AND AVAILABLE FOR IMMEDIATE DESPATCH



203 Foley Industrial Estate, Off Beauchamp Avenue,
Kidderminster, Worcestershire DY11 7DH
Tel : (01562) 823034 • Fax : (01562) 829787
email : sales@exilco.co.uk

All EXILCO Warning Labels conform to BS5378 and I.E.E. Regs. 16th edition and BS7671:2004 amendment 2, where applicable